



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110115, Building Permit - Commercial
Address: 970 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Passed	Tuesday, May 03, 2011

Occupancy Inspection - Codes Commercial	John Borns	Partial	Tuesday, May 03, 2011
--	------------	---------	-----------------------

Corrective Action Required
1 MISC

GAS SERVICE ENTRY ADDRESS MARKING TO BE COMPLETED
PER DISCUSSION

Corrective Action Required
2 MISC

CIRCUIT BREAKER POSITION NUMBERS AT HV ELECTRICAL
PANEL NOT NUMBERED

Corrective Action Required
3 MISC

"NO SMOKING" SIGN TO AFFIXED TO PUBLIC ENTRY DOOR

Corrective Action Required
4 MISC

ROOFTOP FINAL CLEANUP TO BE VERIFIED

Alarm Test	Joe Dir	Passed	Tuesday, May 03, 2011
-------------------	---------	--------	-----------------------

Corrective Action Required
1 MISC

Front of store (girls clothing) light soffit area needs additional sprinkler
heads installed.

Sprinkler - Flow Test Joe Dir

Passed

Tuesday, May 03, 2011

**Occupancy
Inspection - Fire** Joe Dir

Temporary C of O

Tuesday, May 03, 2011

Comments: