

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20222091  
Address: 1936 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:         | Outcome: | Date:                       |
|---|--------------------|----------|-----------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Patrick Schonfeldt | Failed   | Thursday, December 08, 2022 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | -resolve outstanding inspection fees<br>-obtain lawn irrigation system permit<br>-final grade and sod<br>-submit as graded plot plan for review and approval<br>-splash blocks<br>-guardrail required at front porch<br>-set electrical boxes at garage ceiling to and install outlets/cover plates<br>-label all breaker locations at service panel<br>-6'8" head clearance required at basement stairs<br>-1" clearance from combustibles required for b vent at basement |
|---|------|---|

**Comments:**