

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220870  
Address: 900 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Robb Popp	Failed	Thursday, December 08, 2022

**Corrective Action Required:**

1	Misc	-Secure mc at print access, teller, bathroom -Protect dwv within 1.25" of face of framing -Anchor bolts at conference and bath
---	------	--

**Comments:**