



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20110060, Building Permit - Commercial  
Address: 970 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Passed	Tuesday, May 03, 2011

<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Partial	Tuesday, May 03, 2011
--	------------	---------	-----------------------

### Corrective Action Required

1 MISC	ELECTRICAL RECEPTACLES AT RTU'S TO BE TESTED
2 MISC	WALL PENETRATION BY GAS SERVICE LINE NOT SEALED
3 MISC	ADDRESS IDENTIFICATION AT GAS SERVICE ENTRY TO BE APPLIED PER DISCUSSION
4 MISC	PANEL SCHEDULES AT ELECTRICAL SERVICE TO BE COMPLETED
5 MISC	ELECTRICAL RECEPTACLE AT OFFICE NORTH WALL: APPARENT OPEN GROUND
6 MISC	ELECTRICAL RECEPTACLE AT OFFICE NORTH WALL NOT SOLID TO BOX
7 MISC	"NO SMOKING" SIGN REQUIRED
8	ROOFTOP CLEANUP TO BE VERIFIED

<b>Alarm Test</b>	Joe Dir	Passed	Tuesday, May 03, 2011
-------------------	---------	--------	-----------------------

<b>Sprinkler - Flow Test</b>	Joe Dir	Passed	Tuesday, May 03, 2011
------------------------------	---------	--------	-----------------------

<b>Occupancy Inspection - Fire</b>	Joe Dir	Passed	Tuesday, May 03, 2011
--	---------	--------	-----------------------

**Comments: OK TO SET UP FOR BUSINESS. NO PUBLIC UNTIL APPROVED.**