

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213746
Address: 725 SW 15TH CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, December 08, 2022

Corrective Action Required:

1	Misc	-PRESSURE TEST REQUIRED -GAS LINE BOND REQUIRED -GAS LINE NOT ALLOWED TO PENETRATE HVAC AIR RETURN IRC G2415.3
---	------	--

Comments: