

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220353
Address: 3113 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, December 08, 2022

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Address in contrasting colors- Sidewalk inspection pending- Lower water meter lid to grade- Label non gfci outlets garage, basement- Outlet in master bathroom vanity near toilet to be gfci protected- Electrical boxes in ceiling upstairs open- Switch plate missing stairs to basement- Provide anchor bolts steel columns basement |
|---|------|--|

Comments: