CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213548 Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspect	i on Robb Popp	Partial	Friday, December 09, 2022
Corrective Action Requir 1 THIRD FLOOR	AREA A -RC AT UNITS AND C	ORRIDORS	OR
	AREA B: -RC AT UNITS AND C		
	AREA C -RC AT UNITS AND C 314-REPAIR ROCK A	ORRIDORS T CEILING IN KITCHEN	
	AREA D -RC AT UNITS AND C -FIRST AND SECOND	ORRIDORS	IDOR
Corrective Action Requir 2 SECOND FLOO	R AREA A -RC AT UNITS AND C	ORRIDORS AYER CORRIDOR AND UN	ITS

		AREA B -RC AT UNITS AND CORRIDORS-FIRE BLOCK CEILING LINE AT SEPARATION WALLS -1ST AND SECOND LAYER UNITS AND CORRIDOR
Corrective Action Requir 3 FIRST FLOOR		AREA C: -RC AT UNITS AND CORRIDORS 213-REPAIR ROCK AT CEILING BATH AND MECHANICAL 215-REPAIR ROCK AT CEILING KITCHEN AND MECHANICAL
	e Action Required:	AREA D -RC AT UNITS AND CORRIDORS 1st and 2nd layer UNITS AND CORRIDOR
	•	AREA A -RC AT UNITS AND CORRIDOR EXCEPT AS NOTED: 129 INCOMPLETE -1ST LAYER AND SECOND LAYER AT UNITS AND CORRIDOR EXCEPT AS NOTED: 129 INCOMPLETE
		AREA B -CLUBHOUSE TRUSSES OK FOR PRE ROCK -SCREW PATTERN AT AMENITIES CEILINGS -RC FOR UNITS AND CORRIDORS-NO COMMON AREAS -FIRST LAYER AND SECOND LAYER AT UNITS AND CORRIDOR-NO COMMON AREAS
Corrective Action P		AREA C: -RC AT UNITS AND CORRIDORS
	e Action Required:	AREA D -RC AT UNITS AND CORRIDORS
4	STAIR TOWER 1	RC AT STAIR TOWERS A-C COMPLETE

Comments: