

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216203
Address: 2046 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, December 09, 2022

Corrective Action Required:

1	Misc	-provide as graded plot plan -address siding clearance from grade at rear of home must be 6" from grade (this includes sod, rocks, mulch, etc landscaping) and 2" clearance from concrete patio
---	------	--

Comments: