

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222242  
Address: 530 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Commercial</b>	Khanh Nguyen	Failed	Friday, December 09, 2022

Corrective Action Required:

1	Misc	GAS PIPING SYSTEM IS NOT PER APPROVED PLAN. SUBMIT REVISED PLAN TO THE CITY FOR APPROVAL
---	------	--

**Comments:**