CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216145

Address: 4413 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Patrick Schonfeldt Not Ready Monday, December

Residential 12, 2022

Corrective Action Required:

1 Misc -complete all corrections before scheduling, fee added

-TAMPER RESISTANT ELECTRICAL RECEPTACLES REQUIRED PER IRC E4002.14,

NEC 406.12(A)

-AFCI ARC FAULT PROTECTION REQUIRED AT ALL CIRCUIT LOCATIONS PER IRC

E3902.16, NEC 210.12(A) -(not complete see fridge, bar Rec, kitchen,

cooktop/hood, micro, washer circuits)

-PROVIDE HANGERS AND DECK BEAM CONNECTION TO LEDGER PER THE

PLANS, SIMPSON HUCQ210-2-SDS WITH SIMPSON SCREWS, SEE DETAIL A3.0 IN

PLANS (not complete)

Comments: