

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220407
Address: 512 SE CARTER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, December 12, 2022

Corrective Action Required:

1	Misc	-provide an as graded plot plan for lot, concern at rear of lot with grade higher will not allow for drainage of lot at swale rear of lot
		-GFCI protection at dishwasher outlet, outlet testing as hot/ground reverse
		-AFCI protection at kit/dine circuit, breaker not tripping when test button pressed

Comments: