

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215563
Address: 1620 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, December 12, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Obtain an irrigation permit and submit a back flow certification- Splash blocks- Final grading and sod- Garage outlets showing faulty and gfci will not reset- Discharge tube at water heater to be more than 2 times the diameter of pipe but not more than 6" from floor
---	------	--

Comments: