

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220590
Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Grading/Excavation/Fill Inspection	John Jackson	Partial	Monday, December 12, 2022

Corrective Action Required:

1	Misc	12/12/22 Monday JMJ (Complete Excavation/ Remus Conrete) Contractor was grading parking lot area for gravel and Geogrid for stabilization. Complete Excavation during grading foun a bust in the circumference of the new curbs poured on the Southeast side.
---	------	--

Comments: