

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222785  
Address: 1220 NW MAIN ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Robb Popp	Partial	Monday, December 12, 2022

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	ALL INTERIOR PIER PADS COMPLETE  FOOTINGS AT: LINE A COMPLETE LINE 1 AT A-E  **PROVIDE DOCUMENTATION FOR REINFORCEMENT CHANGES FROM APPROVED STRUCTURAL DRAWINGS
---	----------------------------------	--

**Comments:**