

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221353
Address: 3214 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, December 13, 2022

Corrective Action Required:

1	Misc	-seal penetrations into furr down garage W wall (missing spot) -address header cut at pantry for dwv -missing nails in multiple hangers above kitchen (not done) -missing nails in stud shoe in master bath -furr out for dwv in bed 2 bath -address rafter not landing on top plate 2nd floor (provide engineering for fix) -address rafter to ceiling joist connections 2nd floor -seal penetrations in vertical to horizontal fireblocking
---	------	--

Comments: