

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221724
Address: 3219 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Final - Residential	Shawn Hoffman	Failed	Tuesday, December 13, 2022

Corrective Action Required:

1	Misc	- COMPLETE FENCE - SECURE ELECTRICAL RACEWAYS AT PUMP - PROVIDE WATER BOND
---	------	--

Comments: