

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225518
Address: 657 SW 2ND ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Tuesday, December 13, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Complete all corrections for LSFD -Provide 36" working space at electrical panel-Unable to inspect panel at this time, ensure schedule is in place and up to date -Provide restroom signage -Mirror to be max 40" aff to reflective surface -Provide 18" vertical grab bar -Provide open face toilet seat -Provide plumbing protection at sink
---	--------------------------	---

Comments: