

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Failed	Tuesday, December 13, 2022

Corrective Action Required:

1 Misc

***Pre Final units

1A

—Throughout:

- Remove covers and install all sprinkler escutcheons interior and exterior
- Ensure secondary lock at SGD's is operable
- Extend box at master bath mirrors to within 1/4" of finish
- Seal all gaps and penetrations at mechanical room ceilings

12/13/22 units inspected:

133-complete throughout items, provide panel schedule

136-Complete throughout items, latches at SGD

135-Throughout items, secondary latch at SGD, loose receptacle at bath

Comments: