

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216279
Address: 113 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, December 14, 2022

Corrective Action Required:

1	Miscellaneous Correction	I- final grading and sod - Splash blocks - Missing nails on hangers deck joist - Security screws patio door - Protect I-joist basement (max 80 Square feet around mechanical per floor exception). - As graded plot plan needed for retaining wall change
---	-----------------------------	--

Comments: