

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220349
Address: 2027 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, December 14, 2022

Corrective Action Required:

1	Misc	-pay all fees -uncover water meter bring flush to grade -spark ring at dining backsplash outlet -spark ring at outlet above fireplace -spark ring at outlets in trim in master -secondary locking device at rear slider -secure conduit at water heater -secure conduit at A/c unit
---	------	--

Comments: