

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20225403  
Address: 1025 SW REDBUCK CIR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                         | Inspector:    | Outcome: | Date:                        |
|-------------------------------------|---------------|----------|------------------------------|
| <b>Water Service Inspection - R</b> | Shawn Hoffman | Partial  | Wednesday, December 14, 2022 |

Corrective Action Required:  
1 Misc - partial pex through foundation, no tap or meter.

**Comments:**