

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215799
Address: 1509 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, December 14, 2022

Corrective Action Required:

1 Misc

- fireblock ceiling furred down soffit line at master bath vanity seal gaps (see dwv)
- fireblock vertical to horizontal furred down soffit ends(see both bedroom closets check all areas)
- fireblock fireplace lid at basement den/ bed 3(red pex placed in area to identify)

Comments: