

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215799  
Address: 1509 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, December 14, 2022

Corrective Action Required:

1 Misc

- fireblock ceiling furred down soffit line at master bath vanity seal gaps (see dwv)
- fireblock vertical to horizontal furred down soffit ends(see both bedroom closets check all areas)
- fireblock fireplace lid at basement den/ bed 3(red pex placed in area to identify)

**Comments:**