

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220582  
Address: 2323 SW SERENA PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Thursday, December 15, 2022

Corrective Action Required:

1	Misc	- Strap top plate master bedroom at triple 2x12s exterior wall less than 24" over lap
		- Steel column at bottom of stairs plan calls for 3 1/2" (F)

**Comments:**