

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220708  
Address: 3204 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, December 15, 2022

Corrective Action Required:

1 Misc

- address holes drilled in joists closer than 2" at garage entry for pex
- address over notched double floor joist above great room near windows
- address double joists above great room near stairs hole drilled greater than 3"
- address holes drilled closer than 2" in floor joist above great room near stairs

Okay to insulate DO NOT COVER ANY ITEMS STILL IN NEED OF INSPECTION

**Comments:**