

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220428
Address: 3541 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, December 15, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-maintain gravel filter on drive-fireblock vertical to horizontal at furred down soffit garage-fireblock plumbing fur out at garage wall-provide joist hanger at joist to header at basement den-nail off all floor joists at basement den-top plate corner lap at front entry-nail stud shoes master vanity-seal all plate penetrations 2nd floor-12" oc nailing all abutting corners-provide (4) 2x4 stud pack at trpl lvl bearing beneath 1st floor rim joist to support load at foundation-repair B2 truss per engineer letter-min 10 psi pressure at gas service
---	------	--

Comments: