

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222626
Address: 2225 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, December 16, 2022

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none">- Fb penetration top plate return wall at stairs main floor- Fb gaps in solid blocking of mechanical chase at entry wall- Provide Egress windows- Deck not built
---	--------------------------	---

Ok to insulate
Do not rock until fire blocking inspected

Comments: