CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20223626Address:2762 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, December 16, 2022

Corrective Action Required:

1 Misc	 Fb penetrations master at floor vanity, nm, dwv 	
		 Fb penetrations top plate at sliding door main floor
		- Security blocking at sliding door
		- Strap top plate great room near bedroom 2 short over lap
		 Address entry door wall and garage wall not tied at top plate
		- Address entry door wall at bedroom 3 top plate not tied in and no plate
		over lap
		- Tie down double girder at entry door
		 Fb penetration top plate bathroom at bedroom 3 closet
		- Fb vertical every 10' basement bedroom 4

Comments: