

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222619
Address: 2221 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|---------------------------|
| Gas Service Inspection - Residential | Mitchell Schwarz | Failed | Friday, December 16, 2022 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | provide min 10psi at gas pressure gauge for inspection. |
|---|------|---|

Comments: