

FIRE DEPARTMENT

Prevention Division (816)969-1300

PLANS REVIEW CONDITIONS

Permit No: PRCOM20225202 Date: December 16, 2022

Project Title: RADIANT WAXING Applicant:

Location:

880 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086 RED SUMMIT FAIR LLC

Type of Work:

Occupancy Group: B

Description: BODY WAXING SERVICES

Construction Type: Type IIB (Unprotected)

Map Page:

Applicant:

ONE E WASHINGTON ST STE 300, PHOENIX AZ 85004

PHOENIX, AZ 85004

Primary:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review Reviewed By: Ben Hicks Released for Construction

2. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required- Call (816) 969-1300 to schedule a test for before the regular business hours of adjacent tenants.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.