

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220195
Address: 3246 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, December 19, 2022

Corrective Action Required:

1	Misc	-pay all fees -sod -uncover covered manhole -provide correct permit address -splash blocks and sump pump discharge to extend 36" from foundation -Provide hardware for rear slider -spark ring for outlet above fireplace -provide ladder for egress window well to code -provide lockout for all hardwired appliances
---	------	--

Comments: