

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Eric Sharp	Passed	Monday, December 19, 2022

Corrective Action Required:

1	Misc	Forms were placed and aggregate was present and compacted. Still working on getting manhole casting set, so they can pour it in place. . RP 8-19-21
---	------	---

Informational:

2	Misc	Manhole was adjusted and poured in place using 4K KCMMB mix. RP 8-20-21
---	------	---

Informational:

3	Misc	Driveway approaches for the parking lot meets LS and ADA specs. RP 8-27-21..
---	------	--

Comments: