

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081 520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Eric Sharp	Passed	Monday, December 19, 2022

Corrective Action Required:

1	Misc	Shamrock and O'Brien needs to be swept and kept clean. Notified Bertie from Haren on 8/19 about the issue and clean the streets. Roadways still haven't been cleaned yet. If not cleaned today, I will issue a STOP WORK ORDER. RP 8-20-21
---	------	--

Corrective Action Required:

2	Misc	Streets were cleaned, but Geiger truck 337 was washing out and runoff was running down to the curb inlet. Storm drain needs to be cleaned out. RP 8-20-21
---	------	---

Informational:

3	Misc	No erosion issues, but silt fencing is missing. Final grading and sodding should be happening next week. RP 8-27-21
---	------	---

Informational:

4	Misc	No erosion issues to report. RP 9-3-21
---	------	--

Informational:

5	Misc	No erosion issues to report. RP 9-7-21
---	------	--

Corrective Action Required:

6	Misc	Many gutter buddies have either partially or completely fallen into the storm boxes. The few that haven't need to have the silt removed from the front of them. RP 2-10-22
---	------	---

Informational:

7

Misc

Gutter buddies have been replaced and installed where they were missing.
RP 2-15-22...

Comments: