

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215272

Address: 3679 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643679 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643679 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643679 NE AKIN DR, Unit:A, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, December 20, 2022

Corrective Action Required:

1 Misc

UNIT A:

UNIT B:

- Complete master shower plumbing
- Support for plumbing vent above laundry not attached to framing

UNIT C:

- Complete master shower plumbing

UNIT D:

- Seal at plumbing vent roof flashing

Comments: