

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215493
Address: 2023 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, December 20, 2022

Corrective Action Required:

1 Misc

- properly illuminate address
- garage entry door to be self closing and latching
- spark ring at outlet above fireplace
- open junction box above 2nd floor hall
- spark ring at basement bathroom outlet
- address siding from grade at rear of home
- splash blocks

Comments: