CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220570

Address: 1100 NW MAIN ST, Unit:FP, LEES SUMMIT, MO 640861100 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Footing Inspection - Robb Popp Failed Tuesday, December

Commercial 20, 2022

Corrective Action Required:

1 Misc **12/20/22

-PROVIDE CLEARANCE TO BAR FROM EARTH THROUGHOUT, REMOVE

MOISTURE AND TRASH FROM FOOTING

-PROTECT FOOTING FROM FREEZING OVER NIGHT

LINE 10

Comments: