

Third Party Inspection Report

Inspector	Date	Time								
David P. Ainsworth, P.E.	12-15-22	11:30 AM								
Company	Permit #	Permit Holder								
David P. Ainsworth, P.E.	2027 - 4903	HOMES CUSTOM								
Inspection Type	Address HOOK FARMS LOT 132									
SUBGRAPH FOOTING	2607 SW TRACKER LN LSMO									
E-Mail Address dainsworth@chelepis.com										
Instructions: This form must be copermit in Lee's Summit. Submit form Department. If a subsequent inspection that inspection being scheduled.	within 48 hours after inspection to t	the Development Services								
Check all boxes that apply to the site of	onditions and the inspection being	performed.								
Site Conditions:										
Plans stamped by the City on s	site with the plot plan included. (Co	oied plans are not acceptable)								
Erosion controls in place and maintained										
*Note: If these requirements are not r	net no inspection shall be performe	d or accepted by the City.								
Foundations and Footings:	N									
Foundation type and MBOE is	Foundation type and MBOE is equal to or above the plot plan									
Concrete encased electrode (u	Concrete encased electrode (ufer) ground installed (Location must be noted in comments)									
Foundation/Footing meets all City Code requirements and matches City approved plans or engineered design.										
Foundation Walls:										
Elevation is sufficient to achie	ve 2% slope away from structure									
No openings below the MBOE										
Concrete encased electrode (Concrete encased electrode (ufer) ground exposed									
Foundation wall meets all City engineered design.	Foundation wall meets all City Code requirements and matches City approved plans or engineered design.									



grad										
⊫	r	a	ľ	γ	٦	ı	ď	٦	σ	
B		u	ш	u	ш	ij	u	8	85	

Framing meets all City Code requirements and matches City approved plans or engineered design.

*Note: Framing can only be covered after mechanical, electrical, and plumbing inspections have been passed.

Corrective Actions and Comments:

UFER GROUND ROD IS LOCATED IN THE LEFT SIDEWALL ABOUT 4' BACK OF REAR GARAGE WALL. SUBGRADE WAS SOLID WITH SOIL BEARING CAPACITY IN EXCESS OF 3,000 PSF.

I certify that I have inspected, tested, and checked the work performed, and I find the work to be compliant with all applicable City ordinances and approved building plans and site plans and that the all information in this form is both accurate and true.

Signature: March Clinoworth, P.E.

Engineer/Architect Seal

12-15-22