

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215334
Address: 2043 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, December 21, 2022

Corrective Action Required:

1	Misc	NO FURTHER INSPECTIONS UNTIL EROSION CONTROL IS IN COMPLIANCE -erosion control to remain in place until sod -final grade and sod -obtain issued lawn irrigation permit -gutters -splash blocks and sump pump discharge to extend 36" from foundation -security screws at rear door -pressure relief valve pipe on water heater to close to ground
---	------	--

Comments: