

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224485
Address: 1637 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, December 21, 2022

Corrective Action Required:

1	Misc	NO FURTHER INSPECTIONS UNTIL EROSION CONTROL IS IN COMPLIANCE -lib bracing garage E wall -mid way strap all dwv in wall space 2" in diameter or less -fireblock furr out left of great room windows into furr Down -missing nail in hanger above dining
---	------	---

Comments: