

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222245
Address: 1430 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Failed	Wednesday, December 21, 2022

Informational:
1 Misc - TRASH ENCLOSURE FOOTING OK TO POUR -

12/21/22-HAVE REVISED FOUNDATION PLAN ON SITE FOR THE 4 CANOPY
PIERS; CLEAN OUT ALL LOOSE DIRT AND TRASH; INSTALL 3 #3 TIES AT UPPER
END OF PIERS; MIN 3" CLEARANCE OF REBAR FROM SOIL

Comments: