

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213548
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Failed	Wednesday, December 21, 2022

Corrective Action Required:	
1	THIRD FLOOR
	AREA "A"
	UNITS AND CORRIDOR APPROVED
	AREA "B"
	UNITS AND CORRIDOR APPROVED
	AREA "C"
	UNITS AND CORRIDOR APPROVED
	AREA D
	UNITS AND CORRIDOR APPROVED

Corrective Action Required:	
2	SECOND FLOOR
	AREA A
	UNITS AND CORRIDOR APPROVED
	AREA B
	UNITS AND CORRIDOR APPROVED
	AREA C
	UNITS AND CORRIDOR APPROVED

AREA D
UNITS AND CORRIDOR APPROVED

Corrective Action Required:
3 FIRST FLOOR

AREA A
UNITS AND CORRIDOR APPROVED

AREA B
-APPROVED EXCEPT AS NOTED:
119 PROVIDE ANCHOR BOLTS AT EXTERIOR WALL; only see 3 bolts in exterior wall.12/21

AREA C
UNITS AND CORRIDOR APPROVED

AREA D
UNITS AND CORRIDOR APPROVED EXCEPT AS NOTED:
102-NOT READY

Corrective Action Required:
4 ELEVATOR 1

Corrective Action Required:

5 STAIR TOWER 1 COMPLETE

Corrective Action Required:

6 STAIR TOWER 2 COMPLETE

Corrective Action Required:

7 STAIR TOWER 3 COMPLETE

Corrective Action Required:

8 STAIR TOWER 4 COMPLETE

Comments: