

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215279

Address: 3663 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643663 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643663 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643663 NE AKIN DR, Unit:A, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|----------------------------|
| Gas Service Inspection - Commercial | Khanh Nguyen | Failed | Tuesday, December 27, 2022 |

Corrective Action Required:

| | | |
|---|------|-------------------------------------|
| 1 | Misc | Unit A gas test failed. No pressure |
|---|------|-------------------------------------|

Comments: