

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20225390  
Address: 3540 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Patrick Schonfeldt	Failed	Tuesday, December 27, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>-provide grab bars in bathroom per plans</li><li>-no above ceiling inspection performed, remove ceiling tiles and schedule above ceiling inspection for new lighting added</li><li>-mark all current breaker locations at service panel, make all breakers operational (breaker covered with tape)</li><li>-remove all combustible materials and chemicals from mech room</li><li>-cover plates all outlets and switches</li><li>-obtain sign permit</li><li>-make all corrections required for Fire Dept</li></ul>
---	------	---

Comments: