

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224423
Address: 4410 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Patrick Schonfeldt	Failed	Tuesday, December 27, 2022

Corrective Action Required:

1	Misc	SUBMIT REVISED PLANS AND PLACARD THAT REFLECTS ARRAY LAYOUT CHANGES ON SITE
---	------	---

Comments: