

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220114
Address: 2035 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, December 28, 2022

Corrective Action Required:

1	Misc	-complete cspf in dinning provide documentation/engineer letter for alternative cspf design
---	------	---

Method ABW REQUIRES 32" panel length for 9' wall per table 602.10.5
Provide engineered correction

Okay to insulate

Comments: