

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220590
Address: 520 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Partial	Wednesday, December 28, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Provide H2.5s for both plies of double trusses-missing at storage area -Provide truss plans for inspection-Provide all lateral bracing per plans -Provide anchor bolts within 12" of plate breaks at dining- see kitchen area -Solid block and nail horizontal sheathing seams-dining room exterior corner **OK FOR ROCK ON WALLS-DO NOT COVER INSPECITON ITEMS
---	-----------------------------	--

Comments: