

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226242
Address: 807 SE MILLER ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, December 28, 2022

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Fire block fur out vertically every 10'- Fire block top of fur out to joist space- Install electrical panel- Land all electrical wiring- Provide combustion air vents, high and low- All outlets in living areas must be AFCI protected- All electrical to be brought up to 2018 code |
|---|------|---|

Comments: