

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222245
Address: 1430 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------|--------------|----------|---------------------------------|
| Water Line - Coliform Test 1 | John Jackson | Passed | Wednesday, December 28, 2022 |

Informational:
1 Misc 12/28/22 Wednesday JMJ (Reike)
First bacterial test passed last week.

Comments: