

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222619
Address: 2221 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, December 29, 2022

Corrective Action Required:

1 Misc

- fire block bed 5 closet walls and dead space into furr down
- fireblock dead space in basement bath to ceiling space
- fire block flex room walls into ceiling space
- seal penetrations in R/a joist space at bed 4 entry
- seal penetrations in 10' vertical to horizontal fire-blocking(ensure 10' spacing)
- address over notched stud above bed 3 (provide engineer for fix)

Do not insulate

Comments: