

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224434
Address: 2909 NW AUDUBON LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|-----------------------------|
| Pool Steel/Bonding - Residential | Shawn Hoffman | Partial | Thursday, December 29, 2022 |

Corrective Action Required:

| | | |
|---|------|--------------------------------|
| 1 | Misc | Partial |
| | | - bonding at 6 points |
| | | - #4 copper in cover motor pit |
| | | - Copper to pump location |
| | | Ok to pour concrete |

Comments: